

---

## Plan Review Summary

---

### Building Information

Project Name:	Saad Bhamia Lab Fit Up	Floor/Room #:	L2115 & 2350
Building #:	147	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$388,000.00
Construction Type:	Choose an item.	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Kyle Epstein
Construction Manager:	Mitchell Shelton
Aim Project Number:	0376-2017

---

### Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	1/11/2018
Disposition:	Approved	Date Completed:	2/7/2018

---

### Status Statement

Note: Fire alarm tier 1 modifications as part of a permitted construction project

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm:2018-FA-010
-