
Plan Review Summary

Building Information

Project Name:	Lily Cheung Lab Fit Up	Floor/Room #:	1321 & 1351
Building #:	147	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$2000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	Kyle Epstein
Construction Manager:	Mitchell Shelton
Aim Project Number:	0377-2017

Reviewer Information

Reviewer Name:	Larry Labbe	Date Received:	1/11/2018
Disposition:	Approved	Date Completed:	2/7/2018

Status Statement

Note: Fire alarm tier 1 modifications as part of a permitted construction project.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm: 2018-FA-011
-