

---

## Plan Review Summary

---

### Building Information

Project Name:	BME Mitchell Lab Renovations	Floor/Room #:	3rd Floor
Building #:	165	Department:	Biomedical Engineering
Occupancy Type:	Business	Budget:	\$300,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

---

### Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Kynthia Gaines
Aim Project Number:	0367-2017

---

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/12/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/7/2018

---

### Status Statement

Note: The BME Mitchell Lab Renovations fire alarm modifications.

### Review Comments:

1. When testing the fire alarm system a 24 hour notification must be given to all occupants. Proper signage provided by the fire safety office is required to be posted on all entry/exit doors.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Fire Alarm 2018-FA-014
-