

## Plan Review Summary

### Building Information

|                    |   |                 |              |
|--------------------|---|-----------------|--------------|
| Project Name:      | Highland Bakery Conference Room Soundproofing | Floor/Room #:   | Garden Level |
| Building #:        | 35  | Department:     | CPSM         |
| Occupancy Type:    | Assembly                                      | Budget:         | \$100,000.00 |
| Construction Type: | IIB   | Type of Review: | Fire Alarm   |

### Project Management

|                               |               |
|-------------------------------|---------------|
| Project Manager:              | Liz Punch     |
| Architect/Engineer of Record: | Eric Clementi |
| Construction Manager:         | Liz Punch     |
| Aim Project Number:           | 0135-2017     |

### Reviewer Information

|                |                                     |                 |           |
|----------------|-------------------------------------|-----------------|-----------|
| Reviewer Name: | Cary Redman                         | Date Received:  | 1/19/2018 |
| Disposition:   | Approved w/ Additional Requirements | Date Completed: | 2/5/2018  |

### Status Statement

Note: Additional fire alarm devices in the renovation to the Highland Bakery Conference Room Soundproofing.

### Review Comments:

1. Provide smoke detection in accordance with yellow book requirements unless there's existing smoke detection in place.
2. All alarm testing will require occupant notification 24 hours prior to testing. Proper signage posted on all entry/exit doors shall be picked up at the fire safety office.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Fire Alarm 2018-FA-018