Plan Review Summary

151 Sixth Street, Suite 341

Atlanta, Georgia 30332 404-894-FIRE (3473)

Building Information			
Project Name:	Renovation of Savant(Ivan Allen College)-FA	Floor/Room #:	First Floor
Building #:	038	Department:	Ivan Allen College
Occupancy Type:	Business	Budget:	\$40,000.00
Construction Type:	Choose an item.	Type of Review:	Fire Alarm
Project Management			
Project Manager:	Nicolas Palfrey		
Architect/Engineer of	Record: Jeffery Poole		
Construction Manage	er: Nicolas Palfrey		
Aim Project Number:	0260-2016		
Reviewer Information			
Reviewer Name:	Cary Redman	Date Received:	1/26/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	2/13/2018

Status Statement

Note: The Renovation of Savant(Ivan Allen College)-FA plans.

Georgia Environmental Tech Health & Safety

Fire Safety

Review Comments:

- 1. Sheet F-000 The AHU duct detectors shall send a supervisory signal to the panel and central station.
- 2. Provide manufacture specification documentation for FACP and all devices.
- All fire alarm testing must be approved by the fire safety office. All occupants shall be notified at least 24 hours prior to testing. The fire safety office will provide proper fire alarm testing signage for all entry/exit doors that will need to be placed within 24 hours of testing.
- 4. A weatherproof strobe is required on the building exterior near the designated entrance (the entrance nearest the remote annunciator).

General Note:

- 1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request
- 2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

- 1. Fire Safety Office Project Kick-Off Meeting
- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Alarm 2018-FA-030