

## Plan Review Summary

### Building Information

Project Name:	Center Street Fire Alarm Upgrade	Floor/Room #:	Click here to enter text.
Building #:	132	Department:	Gt Housing
Occupancy Type:	Apartment Building	Budget:	\$750,000
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Fisher Engineering
Construction Manager:	
Aim Project Number:	0184-2017

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	2/26/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	3/29/2018

### Status Statement

Note: The new Center Street Fire Alarm Upgrade.

### Review Comments:

1. A weatherproof strobe is required on the building exterior near the designated entrance (the entrance nearest the remote annunciator).
2. All devices in sleeping areas shall produce a low frequency alarm signal. (NFPA 72 Chapter 18 section 18.4.5.3)

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm 2018-FA-062