

## Plan Review Summary

### Building Information

Project Name:	Wardlaw 053F Offices-Fire Alarm	Floor/Room #:	053F
Building #:	047	Department:	Institute Communications
Occupancy Type:	Business	Budget:	\$3,200
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Amber Chellis-Omedo
Construction Manager:	Fenella Bryant
Aim Project Number:	0107-2018

### Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	3/29/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/11/2018

### Status Statement

Note: Thr Wardlaw 053F Offices-Fire Alarm plans.

### Review Comments:

1. A 24 hour notice shall be posted on all entry/exit doors for all testing. Notices can be picked up at the Fire Safety Office.
2. All new devices must match existing devices and sync together.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Fire Alarm 2018-FA-097

