

Plan Review Summary

Building Information

| | | | |
|--------------------|--|-----------------|------------|
| Project Name: | J. Rimoli Lab Fit Up-Montgomery Knight | Floor/Room #: | Room 106 |
| Building #: | 101 | Department: | Aerospace |
| Occupancy Type: | Business | Budget: | \$2,000 |
| Construction Type: | IIA | Type of Review: | Fire Alarm |

Project Management

| | |
|-------------------------------|------------------------|
| Project Manager: | Maria Del Mar Ceballos |
| Architect/Engineer of Record: | Maria Del Mar Ceballos |
| Construction Manager: | Mitchell Shelton |
| Aim Project Number: | 0019-2018 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 4/4/2018 |
| Disposition: | Approved | Date Completed: | 4/11/2018 |

Status Statement

Note: Fire Alarm: Install 2 smoke detectors and 1 horn strobe

Review Comments:

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

