

## Plan Review Summary

### Building Information

Project Name:	Gilbert Hillhouse Boggs-First Floor Renovation	Floor/Room #:	First Floor
Building #:	103	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$31,000
Construction Type:	Choose an item.	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Will Friedman
Construction Manager:	Nicolas Palfrey
Aim Project Number:	C 0310-2017

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/12/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/17/2018

### Status Statement

Note: First Floor Renovations – Strobes, smokes and horns

### Review Comments:

1. All penetrations in fire rating walls must be sealed with proper seals

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation

3. Fire Alarm

**Permits Issued:**

1. Demolition
  2. Construction / Interior Renovation 2018-CP-119
  3. Fire Alarm
- 

