

Plan Review Summary

Building Information

Project Name:	Bunger Henry Prime Lab 341-Revision	Floor/Room #:	3rd Floor
Building #:	086	Department:	College Of Engineering
Occupancy Type:	Business	Budget:	\$2,500
Construction Type:	IIB	Type of Review:	Fire Alarm-Revision

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Ngugi Mathu
Construction Manager:	Fenella Bryant
Aim Project Number:	0179-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/17/2018
Disposition:	Approved	Date Completed:	4/18/2018

Status Statement

Note: Prime Lab revision for smoke and strobes

Review Comments:

1. No comments

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2018-FA-124
2. Fire Alarm