

Plan Review Summary

Building Information

Project Name:	Locker Room Renovation-Fire Alarm	Floor/Room #:	Locker Room-First Floor
Building #:	017	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	4M
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	Steve Barbaro/One Path
Construction Manager:	Bryan Steed
Aim Project Number:	2018-0050

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	4/18/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	4/20/2018

Status Statement

Note: Fire Alarm for locker room - Boys

Review Comments:

1. F/A batteries must be marked with mfg date with a permanent marker with contrasting color on side.
2. Horn strobe in pool equipment room needs to be changed due to the environmental conditions

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation: 2018-FA-127
2. Fire Alarm