
Plan Review Summary

Building Information

Project Name:	GTRI 1645 Baker Building-2nd Floor Expansion	Floor/Room #:	2nd Floor Expansion
Building #:	099	Department:	GTRI
Occupancy Type:	Business	Budget:	\$11,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Concord Project Consulting, Inc.
Construction Manager:	Jennifer Disotell
Aim Project Number:	0223-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	4/26/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/3/2018

Status Statement

Note: Fire Alarm additions to GTRI 1645 Baker Building- 2nd floor; horn/strobes and smoke detectors; power supply+++++

Review Comments:

1. A thru penetration detail of an approved method of firestopping shall be on site for inspection.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm; 2018-FA-142
-

