

## Plan Review Summary

### Building Information

Project Name:	Parker Biotechnology-Petit Office Renovation 1104 & 1109	Floor/Room #:	1104 & 1109
Building #:	146	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$50,000
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Maria Del Mar Ceballos
Architect/Engineer of Record:	Maria Del Mar Ceballos
Construction Manager:	Fenella Bryant
Aim Project Number:	0115-2018

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/1/2018
Disposition:	Approved	Date Completed:	5/7/2018

### Status Statement

Note: Add smoke detector and fire alarm strobe rooms 1104 and 1109

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

### Permits Issued:

1. Fire Alarm: 2018-FA-155