

Plan Review Summary

Building Information

Project Name:	Edge Dining Hall Renovation-Fire Alarm	Floor/Room #:	2nd Floor
Building #:	18	Department:	AA
Occupancy Type:	Business	Budget:	\$1,000,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Make 3 Jim Winer
Construction Manager:	Fenella Bryant
Aim Project Number:	0299-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/3/2018
Disposition:	Approved	Date Completed:	5/7/2018

Status Statement

Note: Edge Dining Hall Renovation-Fire Alarm

Review Comments:

1. None noted

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Alarm

Permits Issued:

1. Construction / Interior Renovation 2018-FA-161
2. Fire Alarm