

## Plan Review Summary

### Building Information

Project Name:	CREATE-X Renovation at Woody's-Fire Alarm	Floor/Room #:	1
Building #:	116	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$15,000.00
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Becky Williams, HLG Studio
Construction Manager:	
Aim Project Number:	0089-2018

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/22/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/22/2018

### Status Statement

Note: Fire alarm additions to Woodruff Dining Hall

### Review Comments:

1. Please provide a smoke detector in the Janitor's Closet to be in compliance with the Georgia Tech Yellow Book Standards 283100 Fire Detection and Alarm considering this is a normally unoccupied space.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System
2. Fire Alarm

### Permits Issued:

1. Fire Alarm: 2018-FA-195

