
Plan Review Summary

Building Information

Project Name:	Edge Intercollegiate Athletic Center	Floor/Room #:	Ground/G11
Building #:	018	Department:	Event Ops and Facilities
Occupancy Type:	Business	Budget:	\$1,600
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Christie Hughes
Architect/Engineer of Record:	
Construction Manager:	Tyler White
Aim Project Number:	0325-2017

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/8/2018
Disposition:	Approved	Date Completed:	Click here to enter a date.

Status Statement

Note: add strobe and smoke detector to office

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System
2. Fire Alarm

Permits Issued:

1. Fire Alarm: 2018-FA-210
-