
Plan Review Summary

Building Information

Project Name:	A French-Office 001 Renovation-Fire Alarm	Floor/Room #:	Basement
Building #:	30	Department:	Administration & Finance
Occupancy Type:	Business	Budget:	\$105,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Maria De Mar Ceballos
Construction Manager:	Fenella Bryant
Aim Project Number:	0144-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/19/2018
Disposition:	Approved	Date Completed:	6/19/2018

Status Statement

Note: added smoke detector

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm: 2018-FA-221
-