

Plan Review Summary

Building Information

Project Name:	MRDC 2200 Pod Renovation Studio	Floor/Room #:	2nd Floor
Building #:	135	Department:	Mechanical Engineering
Occupancy Type:	Business	Budget:	\$750,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	HLG Studio Architects
Construction Manager:	Cristina Fannin
Aim Project Number:	0067-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/19/2018
Disposition:	Approved	Date Completed:	6/19/2018

Status Statement

Note: Fire Alarm

Review Comments:

1. No comments

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Alarm

Permits Issued:

