

Plan Review Summary

Building Information

Project Name:	Brittain Renovation T Room-Revision	Floor/Room #:	
Building #:	012	Department:	Grand Challenges LLC
Occupancy Type:	Business	Budget:	\$5,100
Construction Type:	IIB	Type of Review:	Fire Alarm-Revision

Project Management

Project Manager:	Spencer Sheffield
Architect/Engineer of Record:	Tyco Simplex Grinnell
Construction Manager:	Spencer Sheffield
Aim Project Number:	0239-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	7/12/2018
Disposition:	Approved	Date Completed:	7/13/2018

Status Statement

Note: Addition of smokes

Review Comments:

1. None

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Alarm

Permits Issued:

1. Demolition
2. Construction / Interior Renovation 2018-FA-252
3. Fire Alarm