
Plan Review Summary

Building Information

| | | | |
|--------------------|---------------------------------|-----------------|----------------------------------|
| Project Name: | Young/Sawicki Lab Renovation-FA | Floor/Room #: | First Floor (high-bay area) |
| Building #: | 126 | Department: | School of Mechanical Engineering |
| Occupancy Type: | Business | Budget: | \$671,000 |
| Construction Type: | IIB | Type of Review: | Fire Alarm |

Project Management

| | |
|-------------------------------|----------------|
| Project Manager: | Kynthia Gaines |
| Architect/Engineer of Record: | Bill Oswell |
| Construction Manager: | Kynthia Gaines |
| Aim Project Number: | 0094-2018 |

Reviewer Information

| | | | |
|----------------|-------------------------------------|-----------------|-----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 7/12/2018 |
| Disposition: | Approved w/ Additional Requirements | Date Completed: | 7/16/2018 |

Status Statement

Note: Fire Alarm Revision: Speaker strobe and smoke detector and monitor module

Review Comments:

1. Please provide an approved method of fire stopping detail through the indicated 1hr. fire rated partitions at the 50/80% inspections.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm: 2018-FA-253