

Plan Review Summary

Building Information

Project Name:	Savant Densification Project for International Education	Floor/Room #:	2nd Floor
Building #:	038	Department:	Other
Occupancy Type:	Business	Budget:	\$14000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Mitchell Shelton
Architect/Engineer of Record:	Lisa Vanderloo
Construction Manager:	Mitchell Shelton
Aim Project Number:	0389-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/17/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	7/18/2018

Status Statement

Note: add horn/strobes to fire alarm system; 2nd floor

Review Comments:

1. An approved method of fire stopping detail shall be required at inspection if thru penetrations exists thru fire rated construction.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm: 2018-FA-259