
Plan Review Summary

Building Information

Project Name:	Smithgall LGBTQIA Resource Center-Fire Alarm	Floor/Room #:	1st Floor
Building #:	123	Department:	Student Services
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Eric Clementi
Construction Manager:	Fenella Bryant
Aim Project Number:	0311-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/25/2018
Disposition:	Approved	Date Completed:	7/26/2018

Status Statement

Note: moved a horn/strobe

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm: 2018-FA-265
-