
Plan Review Summary

Building Information

Project Name:	A/V Upgrades Wardlaw Building-REVISION	Floor/Room #:	Plaza level
Building #:	047	Department:	Office of Development
Occupancy Type:	Business	Budget:	\$260,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Julie Chesnut
Construction Manager:	Kynthia Gaines
Aim Project Number:	0343-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	8/3/2018
Disposition:	Approved	Date Completed:	8/3/2018

Status Statement

Note: Fire Alarm smoke detector and horn/strobe additions

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm: 2018-FA-271
-