

## Plan Review Summary

### Building Information

Project Name:	GTRI 1699-Area 509/513	Floor/Room #:	5th Floor, Area 509/513
Building #:	790	Department:	GTRI
Occupancy Type:	Business	Budget:	\$14,000
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:  
 Architect/Engineer of Record: Spencer Bristol  
 Construction Manager: Jennifer Disotell  
 Aim Project Number: 0483-2018

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	8/14/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	8/15/2018

### Status Statement

Note: Fire Alarm

### Review Comments:

1. Ceiling mounted strobes

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Alarm

### Permits Issued:

1. Demolition
2. Construction / Interior Renovation 2018-FA-282
3. Fire Alarm