
Plan Review Summary

Building Information

| | | | |
|--------------------|--------------------------------------|-----------------|------------|
| Project Name: | GTRI 1676 Family Restroom Renovation | Floor/Room #: | 114 |
| Building #: | 790 | Department: | GTRI |
| Occupancy Type: | Business | Budget: | \$1,000 |
| Construction Type: | IIB | Type of Review: | Fire Alarm |

Project Management

| | |
|-------------------------------|------------------------|
| Project Manager: | |
| Architect/Engineer of Record: | Dennis Carter, Concord |
| Construction Manager: | Jennifer Disotell |
| Aim Project Number: | 0125-2018 |

Reviewer Information

| | | | |
|----------------|--------------|-----------------|----------|
| Reviewer Name: | Jake LeJeune | Date Received: | 9/4/2018 |
| Disposition: | Approved | Date Completed: | 9/4/2018 |

Status Statement

Note: fire alarm; strobe; horn/strobe; pull station

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm: 2018-FA-306
-