

## Plan Review Summary

### Building Information

Project Name:	Skiles 014/014A Interior Renovation	Floor/Room #:	014/014A
Building #:	002	Department:	College of Sciences
Occupancy Type:	Assembly	Budget:	\$89,500
Construction Type:	IIB	Type of Review:	Fire Alarm

### Project Management

Project Manager:	Maria Ceballos
Architect/Engineer of Record:	Maria Ceballos
Construction Manager:	Corey Pressley
Aim Project Number:	0450-2018

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	9/19/2018
Disposition:	Approved	Date Completed:	9/19/2018

### Status Statement

Note: Addition of appliances

### Review Comments:

1. No comments

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Demolition
2. Construction / Interior Renovation
3. Fire Alarm

### Permits Issued:

1. Demolition
2. Construction / Interior Renovation
3. Fire Alarm

2018-FA-314