
Plan Review Summary

Building Information

Project Name:	Global Learning Center (GLC) Lower Level Renovation	Floor/Room #:	Lower Level
Building #:	170	Department:	Professional Education
Occupancy Type:	Business	Budget:	\$650,000
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Amber Chellis-Omedo
Architect/Engineer of Record:	Cythnia Harrison/HLG Studio
Construction Manager:	Cristina Fannin
Aim Project Number:	0097-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	10/29/2018
Disposition:	Approved	Date Completed:	11/1/2018

Status Statement

Note: Strobe additions

Review Comments:

1. Approved

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Alarm 2018-FA-349