

Plan Review Summary

Building Information

Project Name:	Dalney Building-Fire Alarm	Floor/Room #:	All
Building #:	204	Department:	GTRC and Parking & Transportation
Occupancy Type:	Business	Budget:	\$39M
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Brad Morris
Architect/Engineer of Record:	Scott Southerland, Collins Cooper Carusi
Construction Manager:	Fredrik Nilsson, New South Construction
Aim Project Number:	0370-2017

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/1/2018
Disposition:	Approved	Date Completed:	11/2/2018

Status Statement

Note: New Fire Alarm

Review Comments:

1. None

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

- | | |
|---------------|-------------|
| 1. Fire Alarm | 2018-FA-356 |
|---------------|-------------|