

---

## Plan Review Summary

---

### Building Information

Project Name:	Marcus Nano-Lab Wing DGMS Annunciators	Floor/Room #:	Entire Building
Building #:	181	Department:	EH&S
Occupancy Type:	Business	Budget:	\$14,350
Construction Type:	IIB	Type of Review:	Construction-Shop Drawings

---

### Project Management

Project Manager:	Robert Morris
Architect/Engineer of Record:	Greg Spiro
Construction Manager:	
Aim Project Number:	

---

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/6/2018
Disposition:	Approved	Date Completed:	11/7/2018

---

### Status Statement

Note: Gas Detectors/Fire Alarm

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Alarm 2018-FA-365
-