

Plan Review Summary

Building Information

Project Name:	Boggs Room B-69 Renovation	Floor/Room #:	Basement/B-69
Building #:	103	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	Choose an item.	Type of Review:	Fire Alarm

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Becky Williams
Construction Manager:	Fenella Bryant/Cristina Fannin
Aim Project Number:	0002-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/15/2018
Disposition:	Approved	Date Completed:	11/15/2018

Status Statement

Note: Addition strobe, smoke

Review Comments:

1. None

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

- | | |
|---------------|-------------|
| 1. Fire Alarm | 2018-FA-379 |
|---------------|-------------|