

Plan Review Summary

Building Information

Project Name:	BME Graduate Office Renovations-Fire Alarm	Floor/Room #:	Second Floor (2212)
Building #:	165	Department:	Facilities Design and Construction
Occupancy Type:	Business	Budget:	\$1,200
Construction Type:	IIB	Type of Review:	Fire Alarm

Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Bill Oswell
Construction Manager:	Kynthia Gaines
Aim Project Number:	0018-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/3/2018
Disposition:	Approved	Date Completed:	5/7/2018

Status Statement

Note: BME Graduate Office Renovations-Fire Alarm

Review Comments:

- None Noted

General Note:

- Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
- Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

- Fire Alarm

Inspections Required:

- Fire Safety Office Project Kick-Off Meeting
- 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- Construction / Interior Renovation
- Fire Alarm

Permits Issued:

- Construction / Interior Renovation 2018-FA-162
- Fire Alarm

