
Plan Review Summary

Building Information

Project Name:	Mechatronics Relocation	Floor/Room #:	031 Ground Floor
Building #:	50	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$192,000.00
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Bill Oswell
Architect/Engineer of Record:	LAS/Elba St. Romain
Construction Manager:	Bill Oswell
Aim Project Number:	CCO229-2017

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/11/2018
Disposition:	Approved	Date Completed:	2/12/2018

Status Statement

Note: The Mechatronics Relocation renovation and installing a new automatic sprinkler system.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Suppression System 2018-FS-012
-