

151 Sixth Street, Suite 341 Atlanta, Georgia 30332 404-894-FIRE (3473)

Plan Review Summary

Building Information

Project Name: Highland Bakery Conference Rm Soundproofing-FS Floor/

Floor/Room #:

Garden Level

Building #: 35

Department: CPSM

01 OW

Occupancy Type: Assembly

Budget:

\$100,000.00

Construction Type: 713561115

– Daage

Type of Review: Fire Suppression

Project Management

Project Manager:

Liz Punch

Architect/Engineer of Record:

Eric Clementi Liz Punch

Construction Manager: Aim Project Number:

0135-2017

Reviewer Information

Reviewer Name:

Cary Redman

Date Received:

1/19/2018

Disposition:

Approved

Date Completed:

2/5/2018

Status Statement

Note: Relocated sprinkler heads to the sound proofing at the Highland Bakery conference room.

General Note:

1. Inspection requests: http://www.ehs.gatech.edu/fire/inspection-request

2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

Fire Safety Office Project Kick-Off Meeting

- 2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2018-FS-019