

Plan Review Summary

Building Information

Project Name:	Renovation of Savant(Ivan Allen College)	Floor/Room #:	First Floor
Building #:	038	Department:	Ivan Allen College
Occupancy Type:	Business	Budget:	\$39,820.00
Construction Type:	VB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	John Cheek
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0260-2016

Reviewer Information

Reviewer Name:	Cary Redman	Date Received:	1/26/2018
Disposition:	Approved	Date Completed:	2/9/2018

Status Statement

Note: The Renovation of Savant (Ivan Allen College) to add sprinklers to the first floor.

Review Comments:

1. Replace the floor control valve with a butter fly valve.

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Alarm

Permits Issued:

1. Fire Suppression System 2018-FS-029
-

