

Plan Review Summary

Building Information

Project Name:	College of Computing-Lecture Hall 016 Reno-Fire Sprinkler	Floor/Room #:	Ground Floor, Room 016
Building #:	050	Department:	CPSM
Occupancy Type:	Business	Budget:	\$15,179.00
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Jennifer Disotell
Architect/Engineer of Record:	Eric Clementi-SWI
Construction Manager:	Jennifer Disotell
Aim Project Number:	0400-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	5/18/2018
Disposition:	Approved	Date Completed:	5/22/2018

Status Statement

Note: Fire Sprinkler addition for lecture hall College of Computing

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Rough-in
3. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
4. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
5. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

Permits Issued:

1. Fire Suppression System: 2018-FS-193