

## Plan Review Summary

### Building Information

Project Name:	Edge Dining Hall Renovation-Fire Suppression	Floor/Room #:	2nd Floor
Building #:	18	Department:	AA
Occupancy Type:	Business	Budget:	\$1,000,000
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Make3 Jim Winer
Construction Manager:	Fenella Bryant
Aim Project Number:	0299-2018

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	5/24/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	5/24/2018

### Status Statement

Note: Fire Suppression

### Review Comments:

1. Verify that the correct amount of sprinkler heads and wrench per code.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

**Permits Issued:**

1. Construction / Interior Renovation
  2. Fire Suppression System
  3. Fire Alarm
- 

