
Plan Review Summary

Building Information

Project Name:	GT Campus Service Warehouse Reroofing	Floor/Room #:	Roof
Building #:	882	Department:	Housing
Occupancy Type:	Business	Budget:	\$989,000.00
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Daniel Powell
Architect/Engineer of Record:	Lars Finderup; Flynn Finderup Architects
Construction Manager:	
Aim Project Number:	0278-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/1/2018
Disposition:	Approved	Date Completed:	6/1/2018

Status Statement

Note: Add 6 ESFR Fire sprinkler heads

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
2. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System: 2018-FS-203
-