

## Plan Review Summary

### Building Information

Project Name:	Smithgall LGBTQIA Resource Center-Fire Suppression	Floor/Room #:	1st Floor
Building #:	123	Department:	
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Eric Clementi
Construction Manager:	Fenella Bryant
Aim Project Number:	0311-2018

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	6/15/2018
Disposition:	Approved	Date Completed:	6/18/2018

### Status Statement

Note: adding and relocating sprinkler head

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

### Permits Issued:

1. Fire Suppression System: 2018-FS-219