

Plan Review Summary

Building Information

Project Name:	Egde/Rice AD Office Renovation	Floor/Room #:	1st Floor 150
Building #:	18A	Department:	AA
Occupancy Type:	Business	Budget:	\$50,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Eric Clementi
Construction Manager:	Fenella Bryant
Aim Project Number:	303-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	6/25/2018
Disposition:	Approved	Date Completed:	6/28/2018

Status Statement

Note: Addition of sprinkler head

Review Comments:

- None

General Note:

- Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
- Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

- Fire Suppression

Inspections Required:

- Fire Safety Office Project Kick-Off Meeting
- 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
- 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

- Demolition
- Construction / Interior Renovation
- Fire Suppression System

Permits Issued:

- Demolition
- Construction / Interior Renovation
- Fire Suppression System

2018-FS-231