

## Plan Review Summary

### Building Information

Project Name:	Instructional Center-Tennenbaum Auditorium	Floor/Room #:	103
Building #:	55	Department:	Capital Planning & Space Management
Occupancy Type:	Business	Budget:	\$22,214
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Nicolas Palfrey
Architect/Engineer of Record:	Frank Thompson
Construction Manager:	Nicolas Palfrey
Aim Project Number:	0176-2018

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/9/2018
Disposition:	Approved	Date Completed:	7/10/2018

### Status Statement

Note: Fire Sprinkler Modification GT Auditorium

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. System Flush
3. Sprinkler Pipe Inspections
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Construction / Interior Renovation
2. Fire Suppression System
3. Fire Alarm

### Permits Issued:

1. Fire Suppression System: 2018-FS-248