
Plan Review Summary

Building Information

Project Name:	Smithgall LGBTQIA Resource Center-Fire Suppression	Floor/Room #:	1st Floor
Building #:	123	Department:	Student Life
Occupancy Type:	Business	Budget:	\$200,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Fenella Bryant
Architect/Engineer of Record:	Eric Clementi
Construction Manager:	Fenella Bryant
Aim Project Number:	0311-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/23/2018
Disposition:	Approved	Date Completed:	7/23/2018

Status Statement

Note: Revision; Sprinkler head modification

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System: 2018-FS-264
-