
Plan Review Summary

Building Information

Project Name:	Dr. Hu Lab-Fit Up Ford ES&T	Floor/Room #:	2321
Building #:	147	Department:	College of Engineering
Occupancy Type:	Business	Budget:	\$248,600
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Kyle Epstein
Construction Manager:	Mitchell Shelton
Aim Project Number:	0263-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	7/31/2018
Disposition:	Approved	Date Completed:	8/2/2018

Status Statement

Note: Fire Sprinkler modification

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System: 2018-FS-270
-