

## Plan Review Summary

### Building Information

Project Name:	Kendeda Building-Fire Suppression	Floor/Room #:	
Building #:	210	Department:	Facilities
Occupancy Type:	Business	Budget:	\$18.6M
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	John DuConge
Architect/Engineer of Record:	Lord Aeck Sargent (re: Joshua Gassman)
Construction Manager:	Skanska (re: Matt Williams)
Aim Project Number:	0418-2017

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/10/2018
Disposition:	Approved	Date Completed:	9/11/2018

### Status Statement

Note: Install Fire Sprinkler System

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
7. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
8. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Issued:

1. Fire Suppression System: 2018-FS-307