
Plan Review Summary

Building Information

Project Name:	GTRI Cobb South-Building 762	Floor/Room #:	Floors 1-4
Building #:	762	Department:	GT Design and Construction
Occupancy Type:	Business	Budget:	\$24M
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Lindsey Cottingham
Architect/Engineer of Record:	FLAD Architects/Structural
Construction Manager:	Dan Hesse/McCarthy Building Companies
Aim Project Number:	0320-2016

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	9/19/2018
Disposition:	Approved	Date Completed:	10/10/2018

Status Statement

Note: Fire sprinkler system renovation

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2018-FS-315
-