
Plan Review Summary

Building Information

Project Name:	Stamps Commons Expansion-Auditions REVISION	Floor/Room #:	1ST FLOOR
Building #:	114	Department:	GT Dining
Occupancy Type:	Business	Budget:	\$2185
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Malte Weiland
Architect/Engineer of Record:	Craig Wiggins
Construction Manager:	
Aim Project Number:	

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/8/2018
Disposition:	Approved	Date Completed:	10/9/2018

Status Statement

Note: hood fire suppression system

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

1. Fire Suppression System 2018-FS-329
-