

Plan Review Summary

Building Information

Project Name:	ACC Network Operations Center-Sprinkler Dwgs	Floor/Room #:	1st & 2nd Floors
Building #:	32	Department:	GT Athletics Association
Occupancy Type:	Business	Budget:	\$10,000,000
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Cala Barbour
Architect/Engineer of Record:	Jim Winer-Make3
Construction Manager:	Carla Barbour
Aim Project Number:	C0404-2018

Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	10/9/2018
Disposition:	Approved	Date Completed:	10/11/2018

Status Statement

Note: Fire Sprinkler System

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
7. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
8. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Issued:

- | | |
|----------------------------|-------------|
| 1. Fire Suppression System | 2018-FS-331 |
|----------------------------|-------------|