

Plan Review Summary

Building Information

| | | | |
|--------------------|--|-----------------|------------------|
| Project Name: | ISyE Annex Van Hentenryck Computational Lab Renovation | Floor/Room #: | 01/122 |
| Building #: | 057 | Department: | ISyE |
| Occupancy Type: | Business | Budget: | \$157,957.00 |
| Construction Type: | IIB | Type of Review: | Fire Suppression |

Project Management

| | |
|-------------------------------|------------------|
| Project Manager: | Mitchell Shelton |
| Architect/Engineer of Record: | William Oswell |
| Construction Manager: | Jason Strane |
| Aim Project Number: | 0418-2018 |

Reviewer Information

| | | | |
|----------------|----------------|-----------------|-----------|
| Reviewer Name: | Jerry Marrison | Date Received: | 11/7/2018 |
| Disposition: | Approved | Date Completed: | 11/7/2018 |

Status Statement

Note: Addition of heads

Review Comments:

1. Approved

General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: http://www.ehs.gatech.edu/fire/permit-request/hot_work

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Sprinkler Pipe Inspections
3. Rough-in
4. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
5. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
6. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System