
Plan Review Summary

Building Information

Project Name:	Shu Jia Lab-U A Whitaker	Floor/Room #:	Rooms 2220 and 2222
Building #:	165	Department:	Biomedical Engineering
Occupancy Type:	Business	Budget:	\$367,500
Construction Type:	IIB	Type of Review:	Fire Suppression

Project Management

Project Manager:	Kynthia Gaines
Architect/Engineer of Record:	Nerissa Jemmotte, HERA Studio
Construction Manager:	Kynthia Gaines
Aim Project Number:	0487-2018

Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/9/2018
Disposition:	Approved	Date Completed:	11/9/2018

Status Statement

Note: Sprinkler head change

Review Comments:

1. Approved

Plan / Shop Drawings Required:

1. Fire Suppression

Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
3. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

Permits Required:

1. Fire Suppression System

Permits Issued:

1. Fire Suppression System 2018-FS-372
-