

---

## Plan Review Summary

---

### Building Information

Project Name:	Boggs Room B-69 Renovation	Floor/Room #:	Basement/B-69
Building #:	103	Department:	College of Sciences
Occupancy Type:	Business	Budget:	\$150,000
Construction Type:	IIB	Type of Review:	Fire Suppression

---

### Project Management

Project Manager:	Ngugi Mathu
Architect/Engineer of Record:	Becky Williams
Construction Manager:	Fenella Bryant/Cristina Fannin
Aim Project Number:	0002-2018

---

### Reviewer Information

Reviewer Name:	Jerry Marrison	Date Received:	11/15/2018
Disposition:	Approved	Date Completed:	11/15/2018

---

### Status Statement

Note: Addition of 2 heads

### Review Comments:

1. None

### Plan / Shop Drawings Required:

1. Fire Suppression

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
3. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)
4. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

### Permits Required:

1. Fire Suppression System

### Permits Issued:

1. Fire Suppression System 2018-FS-380
-