

## Plan Review Summary

### Building Information

Project Name:	Kappa Alpha Theta-Fire Suppression	Floor/Room #:	All 3 Floors
Building #:	Not yet assigned	Department:	Greek Life
Occupancy Type:	Apartment Building	Budget:	\$4.8M
Construction Type:	IIB	Type of Review:	Fire Suppression

### Project Management

Project Manager:	Tyler White
Architect/Engineer of Record:	Hug & Associates
Construction Manager:	Daniel Powell
Aim Project Number:	-

### Reviewer Information

Reviewer Name:	Jake LeJeune	Date Received:	11/19/2018
Disposition:	Approved w/ Additional Requirements	Date Completed:	11/19/2018

### Status Statement

Note: Fire Sprinkler installation

### Review Comments:

1. Please provide at inspection an approved method of firestopping detail for through penetrations in fire rated construction.

### General Note:

1. Inspection requests: <http://www.ehs.gatech.edu/fire/inspection-request>
2. Hot Work Permit Request: [http://www.ehs.gatech.edu/fire/permit-request/hot\\_work](http://www.ehs.gatech.edu/fire/permit-request/hot_work)

### Additional Requirements (as needed):

1. Fire Emergency Response Plans
2. Red Book Completion and Fixed Location Designation

### Plan / Shop Drawings Required:

1. Fire Suppression
2. Fire Alarm

### Inspections Required:

1. Fire Safety Office Project Kick-Off Meeting
2. Thrust Block Inspections
3. Underground Pressure Test
4. System Flush
5. Sprinkler Pipe Inspections
6. Rough-in
7. 50% Wall (Rated walls, doors, dampers, horizontal penetrations, etc.)
8. 80% Ceiling, Alarm, Sprinkler (vertical penetrations, junction boxes, lights tied at corners, sprinkler and fire alarm roughed in, etc.)

9. 100% Construction, Alarm Commissioning, Sprinkler Commissioning, Certificate of Occupancy (all work complete, commissioning of systems, close-out documents, etc.)

**Permits Required:**

1. Demolition
2. Construction / Interior Renovation
3. Fire Suppression System
4. Fire Alarm

**Permits Issued:**

1. Fire Suppression System 2018-FS-382
- 

